



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/26/2022
Received: 10/13/2022
Sampled By: MaryEllen Rasmussen
Work Order: 2287002

Paid CC

C MITCH Charter School
L Attn: -
I 19550 SW 90th Ct
E Tualatin OR, 97223
N Phone: (503) 639-5757
T

Project:
Project # : -
Sample Type :

Sampling Location: MITCH Charter School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2287002-01	Sample Name: Kitchen Sink Sampled: 10/7/22 10:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15
2287002-02	Sample Name: Avi Classroom Sink Sampled: 10/7/22 10:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15
2287002-03	Sample Name: Gym Sink Sampled: 10/7/22 10:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15
2287002-04	Sample Name: Staff Bathroom 1 Sink Sampled: 10/7/22 10:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15
2287002-05	Sample Name: Staff Bathroom 2 Sink Sampled: 10/7/22 10:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15
2287002-06	Sample Name: K-2 Girls Bath Sink Sampled: 10/7/22 10:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15
2287002-07	Sample Name: K-2 Boys Bath Sink Sampled: 10/7/22 10:00		Matrix: Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	10/24/22 16:15
2287002-08	Sample Name: 3-5 Girls Bath Sink Sampled: 10/7/22 10:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15
2287002-09	Sample Name: 3-5 Boys Bath Sink Sampled: 10/7/22 10:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15
2287002-10	Sample Name: Office Water Fountain Top Sampled: 10/7/22 10:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/26/2022
Received: 10/13/2022
Sampled By: MaryEllen Rasmussen
Work Order: 2287002

Paid CC

C MITCH Charter School
L Attn: -
I 19550 SW 90th Ct
E Tualatin OR, 97223
N Phone: (503) 639-5757
T

Project:
Project # : -
Sample Type :

Sampling Location: MITCH Charter School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2287002-11	Sample Name: Office Water Fountain Bottom Sampled: 10/7/22 10:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15
2287002-12	Sample Name: Gym Water Fountain Top Sampled: 10/7/22 10:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15
2287002-13	Sample Name: Gym Water Fountain Bottom Sampled: 10/7/22 10:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	10/24/22 16:15

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director